




1. ALL JOINTS BETWEEN POINT (A) & POINT (B) IS TO BE MEGALUG MECHANICALLY RESTRAINED JOINTS. SEE SECTION 02224 PART 2 2.04 FOR INSIDE CASING.
2. ALL 45° BENDS SHALL BE ROLLED TO ACHIEVE 5' HORIZONTAL OFF SET.
3. THIS TYPE OF LOOPING SHALL BE APPROVED BY PUBLIC UTILITIES PRIOR TO INSTALLATION



1 2 3	RSS CC CC	UPDATE UPDATE UPDATE	12/1999 1/2010 4/2013	 <p>STANDARD DETAIL FIGURE 06A STEEL CASING WATER LOOP TYPICAL INSTALLATION</p>	SCALE: NONE
NO.	AUTHORIZED BY	REVISIONS	DATE		